


### TYPICAL SECTION

#### NOTES:

- 1.) THICKNESS OF PAVEMENT SECTION TO BE DETERMINED BY R VALUE TESTING PER CALTRANS DESIGN METHOD TEST 301 WITH RECOMMENDED SAFETY FACTOR, MINIMUM 0.50' AC / 1.00' CAB. AC SHALL BE PLACED IN LIFTS, AND THICKNESS OF EACH LIFT SHALL NOT EXCEED 3".
- 2.) MINIMUM T.I. = 10.
- 3.) HALF WIDTH STREETS SHALL BE CONSTRUCTED TO A WIDTH OF 1/2 STREET WIDTH PLUS 18'.

NOT TO SCALE



RECOMMENDED:

EL

DIVISION MANAGER

9/29/18  
DATE

APPROVED:

M2. Woff

9/14/18  
DATE

PUBLIC WORKS DIRECTOR /  
CITY ENGINEER

## CITY OF MORENO VALLEY

PUBLIC WORKS DEPARTMENT - TRANSPORTATION ENGINEERING DIVISION

### INDUSTRIAL COLLECTOR

STANDARD PLAN

**MVSI-106A-0**

SHEET 1 OF 2